

TEST REPORT

ULR-TC596126700005665F

Doc. No : GTL/D/7.5/02

Page 1 of 2

Report Issued To : Ankur International School. Opp. Ashirwad Floor, Nr. Express Highway Road New Maninagar-382449, Ahmedabad,, Gujarat Phone No : 9797976063 Email : .	Test Report No : GTL/03260618030 Date of Receipt : 15/06/2026 Date of Issue : 18/06/2026 Customer's Ref. No : N.M
---	--

Sample Described as : Drinking Water	Mfg. Date : N.M.
Sample Qty : 2.0 Ltr	Exp. Date : N.M.
Packing Mode : Sample Packed In Plastic Bottle	B.No : N.M.
Sample Condition : Satisfactory	
Marking : N.M	
Sample Drawn By : Customer	
Date of Starting of Test : 15/06/2026	Date of Completion : 18/06/2026

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit In the Absense of Alternate Source	Result	Quant. Limit	Test Method
Chemical Water						
1	Colour, Hazen Unit	Max. 5	Max. 15.0	<1	1	IS:3025(P-4)
2	Odour	Agreeable	Agreeable	Agreeable	—	IS:3025(P-5)
3	pH at 25 Deg C	6.5 to 8.5	No Relaxation	7.13	1	IS:3025(P-11)
4	Taste	Agreeable	Agreeable	Agreeable	—	IS:3025(P-7 & 8)
5	Turbidity, NTU	Max. 1.0	Max. 5.0	<0.1	0.1	IS:3025(P-10)
6	Total Dissolved Solids, mg/l	Max.500	Max.2000	74	5	IS:3025(P-16)
7	Calcium (as Ca), mg/l	Max.75	Max.200	6.47	0.1	IS:3025(P-40)
8	Chloride (as Cl), mg/l	Max.250	Max. 1000	9.92	0.5	IS:3025(P-32)
9	Fluoride (as F) mg/l	Max. 1.0	Max. 1.5	B.L.Q.	0.01	IS:3025(P-75)
10	Magnesium (as Mg), mg/l	Max. 30	Max. 100	5.84	0.1	IS:3025(P-46)
11	Nitrate (as NO3) mg/l	Max. 45.0	No Relaxation	B.L.Q.	1	IS:3025(P-34)
12	Phenolic Compounds (as C6H5OH) mg/l	Max. 0.001	Max. 0.002	B.L.Q.	0.001	IS:3025(P-43) Sec 1
13	Sulphate (as SO4), mg/l	Max. 200	Max. 400	B.L.Q.	0.5	IS:3025(P-24 Sec-1)
14	Total Hardness (as CaCO3), mg/l	Max. 200	Max. 600	36.38	1	IS:3025(P-21)
Biological Water						
1	Total Coliform per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	—	IS 15185 : 2016

Note : General Terms & Conditions as mentioned overleaf

Test Report No : GTL/03260618030

Doc. No : GTL/D/7.5/02

Page 2 of 2

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absence of Alternate Source	Result	Quant. Limit	Test Method
2	E.coli per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	---	IS 15185 : 2016

Remark : Sample Found CONFORM as per IS:10500-2012 (Acceptable Limit) with Amendment NO-4 for the tested parameters.

Note : N.M.=Not Mentioned, B.L.Q.=Below Limit of Quantification



For NABL Scope



Mamta Bhavsar



Reviewed By



For Verification

*** END OF REPORT ***

FOR, GUJARAT TESTLAB PVT. LTD

Rupesh Desai-Trupti Thakor

Autho. Signatory